



**CITY OF HOUSTON
FIRE PREVENTION DIVISION
HOUSTON FIRE DEPARTMENT**



**LIFE SAFETY BUREAU (LSB) STANDARD 14
UNATTENDED SERVICE STATIONS**

SUPERCEDES: HFD STANDARD 52-1 (5/21/99)

APPROVED BY:



**DANIEL H. PRUITT
ASSISTANT FIRE MARSHAL**

DATE:

5-23-03

APPROVED BY:



**E. A. CORRAL
FIRE MARSHAL**

DATE:

5-25-03

APPROVED BY:



**CHRIS CONNEALY
FIRE CHIEF**

DATE:

5-28-03

LSB STANDARD 14
UNATTENDED SERVICE STATIONS
CONTENTS

SECTION 1 --- GENERAL

	PAGE
1.1 Scope	2
1.2 Purpose	2

SECTION 2 --- DEFINITION

2.1 Unattended Service Station	2
--------------------------------------	---

SECTION 3 --- REQUIREMENTS

3.1 Fire alarm system	2
3.2 Telephone	3
3.3 Emergency sign	3
3.4 Canopy	3
3.5 Written operation and safety instructions	3
3.6 No Smoking Stop Engine signs	3
3.7 Fire protection	3

REFERENCES	4
-------------------------	---

LSB STANDARD 14

UNATTENDED SERVICE STATIONS

SECTION 1 --- GENERAL

1.1 Scope.

Unattended Service Stations shall be in accordance with the *Fire Code*, this standard and the State Health and Safety Code on Flammable Liquids. Such facilities shall conform to pertinent sections of NFPA Standards 30 and 30-A. Where this is a conflict with this standard and these other requirements, the most restrictive standard shall apply.

1.2 Purpose.

This standard shall provide guidelines for the installation of Unattended Service Stations. Requirements for such Unattended Service Stations are in addition to the *Fire Code* requirements relative to service stations and are subject to approval of the Fire Marshal's appointed committee to review such installations.

SECTION 2 --- DEFINITIONS

2.1 Unattended Service Station.

Unattended Service Stations are service stations not engaged in the retail sale of flammable liquids to the general public and are without an attendant or supervisor on location to monitor dispensing. These stations are classified as private clubs, selling only to members.

SECTION 3 --- REQUIREMENTS

3.1 Fire Alarm.

A fire alarm system shall be required and shall provide the following:

- 1) Control panel
- 2) Pull stations
- 3) Audible devices
- 4) Combination fixed temperature and rate of rise detectors (spacing in accordance with listing requirements)
- 5) System must be weatherproof.
- 6) Automatic fuel shut-off when the fire alarm is activated. These devices will remain inactive until controls are manually re-set at a service location onsite and accessible only by the proprietor or the proprietors designee.
- 7) The system shall be connected to a Underwriters Laboratory (UL) listed central station.

3.2 Telephone.

A readily accessible telephone not requiring a coin to operate shall be provided to notify the Houston Fire Department in case of fire or emergency such as spills.

3.3 Emergency sign.

A sign of durable materials, with letters a minimum of 1-inch in height on a background of contrasting color so that the lettering is clearly visible, shall be posted at the telephone location with the following information:

<p style="text-align: center;">IN CASE OF FIRE, SPILL OR RELEASE</p> <ol style="list-style-type: none">1. Use emergency pump shut-off!2. Report the accident Fire Department No. <u>9-1-1</u> Facility address

3.4 Canopy.

A non-combustible canopy is required to cover all dispensing areas.

3.5 Written operation and safety instructions.

Unattended service stations shall provide written operation and safety instructions to their members and post such instructions in dispensing areas.

3.6 No Smoking and stop engine signs.

Signs, prohibiting smoking, dispensing into unapproved containers, and requiring vehicle engines to be stopped during fueling, shall be conspicuously posted within sight of each dispenser. Sign lettering shall be a minimum of 1-inch in height, on a background of contrasting color, so that the lettering is clearly visible.

3.7 Fire protection.

Two listed portable fire extinguishers with a minimum rating of 20:B each shall be provided and mounted so that both fire extinguishers are readily visible and accessible and so that the path-of-travel distance to either fire extinguisher shall not be more than 35 feet. All fire extinguishers shall be inspected and tagged annually by an approved fire extinguisher service company.

REFERENCES

1. City of Houston *Fire Code*, International Fire Code, 2000 edition, as amended.
2. State of Texas Health and Safety Code, Title 9, Safety Subtitle A. Public Safety, Chapter 753, Flammable Liquids.
3. National Fire Protection Association (NFPA) Standard 30, “Flammable and Combustible Liquids Code”.
4. National Fire Protection Association (NFPA) Standard 30-A, “Automotive and Marine Service Station Code”.

Conversion factors: 1 inch = 25mm; 1 foot = 305 mm